



**DEPARTMENT OF PUBLIC HEALTH AND SOCIAL SERVICES
DIVISION OF ENVIRONMENTAL HEALTH
CHILD CARE FACILITY
INSPECTION REPORT**

INSPECTION	GRADE	INSPECTION DATE	ESTABLISHMENT NAME
Regular <input checked="" type="checkbox"/>	8	1/19/2023	SHINING STARS EARLY CHILDHOOD ACADEMY.
Follow-Up <input type="checkbox"/>		TIME IN	OWNER/OPERATOR
Complaint <input type="checkbox"/>	A	10:50 AM	ROSARIO, JENNETH C
Investigation <input type="checkbox"/>		TIME OUT	LOCATION
Other <input type="checkbox"/>	RATING	11:50 AM	135 PALE MURPHY ST.
		SANITARY PERMIT NO.	TAMUNING GUAM 96913
		220001730	ESTABLISHMENT TYPE
PERMIT STATUS: <input checked="" type="checkbox"/> Valid <input type="checkbox"/> Temporary <input type="checkbox"/> Expired		CCC / NURSERY	
No. of Children: <u>12</u> Male <u>10</u> Female <u>22</u> Total		Child Care License No. <u>220443</u> <input checked="" type="checkbox"/> Valid <input type="checkbox"/> Provisional <input type="checkbox"/> Expired	

The following items identify violations found this day in the operations and facilities which must be corrected by the next inspection, or sooner, as the Department indicates. Non-compliance may result in downgrading or permit suspension. To appeal, a written hearing request must be submitted before the indicated correction date.

ITEM *	REMARKS	DEMERIT	CORRECT BY DATE
	A REGULAR INSPECTION WAS CONDUCTED TODAY. PREVIOUS INSPECTION DATED 12/13/2022 RESULTED IN A GRADE/RATING OF 2/A. PREVIOUS VIOLATION ITEM NO. 24 WAS NOT CORRECTED. THE FOLLOWING WERE OBSERVED:		
17	HOT WATER NOT PROVIDED FOR TODDLER AND PRE-K RESTROOM HAND WASH SINKS. HOT AND COLD RUNNING WATER SHALL BE PROVIDED TO PROMOTE PROPER HANDWASHING AND OVERALL SANITATION.	6	1-29-23
24	WINDOW IN TODDLER S ROOM WAS CRACKED; EXTERIOR DOORS IN INFANT ROOM WERE WITH GAPS, HANDWASH SINK LEAKING IN TODDLER RESTROOM FACILITIES SHALL BE MAINTAINED AND KEPT IN GOOD REPAIR TO PREVENT THE ENTRY OF PESTS AND TO PREVENT PHYSICAL INJURIES/HAZARDS. INFORMED PERSON-IN-CHARGE THAT FAILURE TO COMPLY WITH ANY NOTICE ISSUED IN ACCORDANCE WITH THE PROVISIONS OF ANY APPLICABLE LAWS, RULES, OR REGULATIONS MAY RESULT IN IMMEDIATE SUSPENSION OF THE PERMIT OR THE ESTABLISHMENT DOWNGRADED, PER 10 GCA CHAPTER 21 S. 21107(3). PHOTOS WERE TAKEN "A" PLACARD NO. 04005 WAS REMOVED. "A" PLACARD WAS ISSUED AND POSTED. DISCUSSED THIS REPORT WITH THE PERSON-IN-CHARGE (PIC).	2	1-18-23

I have read and understand the above violation(s) and I am aware of the corrective measures to be taken.

*Note: When any of the following items are cited above, they shall be corrected within ten (10) days of this inspection:
(2), (4), (6), (14), (21), (23), (24), (27), (28), (39), & (40).

RECEIVED BY (Name & Title): Owner 1/19/23
DEH INSPECTOR (Name & Title): S. MENDIOLA, EPHO I gm